

CCPC Impoundment " Ashpond" Weekly Inspection

1	Cracks or Bulges	Yes	<input checked="" type="radio"/> No	Description _____
2	Susidence	Yes	<input checked="" type="radio"/> No	Description _____
3	Wet or Soft Soil	Yes	<input checked="" type="radio"/> No	Description _____
4	Changes in Geometry Elevation of the impounded water and treeboard,	Yes	<input checked="" type="radio"/> No	Description _____
5	depth of sediment and slurry	Description		<u>no change</u>
6	Changes in Vegetation such as being overly lush	Description		<u>no change</u>
7	Obstructive vegetation and trees	Description		<u>NONE</u>
8	Animal burrows	Yes	<input checked="" type="radio"/> No	Description _____
9	Changes to liners	Not Applicable		
10	Spillway Integrity Any other changes which may indicate a potential	Description		<u>O.K</u>
11	compromise to impoundment integrity	Description		<u>NONE</u>
12	Fugitive Dust Issues	Description		<u>NONE</u>

Date Inspection Performed 3-30-20

Inspection Performed by Tommy Miller