

CCPC Impoundment " Ashpond" Weekly Inspection

1	Cracks or Bulges	Yes	No	Description	<u>Betr Removed</u>
2	Susidence	Yes	<input checked="" type="radio"/> No	Description	<u></u>
3	Wet or Soft Soil	Yes	<input checked="" type="radio"/> No	Description	<u></u>
4	Changes in Geometry Elevation of the impounded water and treeboard, depth of sediment and slurry	Yes	No	Description	<u>NO WATER</u>
5				Description	<u>NONE</u>
6	Changes in Vegetation such as being overly lush			Description	<u>NONE</u>
7	Obstructive vegetation and trees			Description	<u>NONE</u>
8	Animal burrows	Yes	<input checked="" type="radio"/> No	Description	<u></u>
9	Changes to liners	Not Applicable			
10	Spillway Integrity			Description	<u>Betr Removed</u>
11	Any other changes which may indicate a potential compromise to impoundment integrity			Description	<u>Betr Removed</u>
12	Fugitive Dust Issues			Description	<u>NONE</u>

Date Inspection Performed 8-23-23

Inspection Performed by Ronnie Miller