

# CCPC Impoundment " Ashpond" Weekly Inspection

1	Cracks or Bulges	Yes	<input checked="" type="radio"/> No	Description	_____
2	Susidence	Yes	<input checked="" type="radio"/> No	Description	_____
3	Wet or Soft Soil	Yes	<input checked="" type="radio"/> No	Description	_____
4	Changes in Geometry Elevation of the impounded water and freeboard,	Yes	<input checked="" type="radio"/> No	Description	_____
5	depth of sediment and slurry	Description	<i>no change</i>	_____	_____
6	Changes in Vegetation such as being overly lush	Description	<i>no change</i>	_____	_____
7	Obstructive vegetation and trees	Description	<i>no change</i>	_____	_____
8	Animal burrows	Yes	<input checked="" type="radio"/> No	Description	_____
9	Changes to liners	Not Applicable			
10	Spillway Integrity Any other changes which may indicate a potential	Description	<i>no change</i>	_____	_____
11	compromise to impoundment integrity	Description	<i>no change</i>	_____	_____

Date Inspection Performed 2-16-16

Inspection Performed by Geo Roges