

CCPC Impoundment " Ashpond" Weekly Inspection

1	Cracks or Bulges	Yes	<input checked="" type="radio"/> No	Description	_____
2	Susidence	Yes	<input checked="" type="radio"/> No	Description	_____
3	Wet or Soft Soil	Yes	<input checked="" type="radio"/> No	Description	_____
4	Changes in Geometry	Yes	<input checked="" type="radio"/> No	Description	_____
5	Elevation of the impounded water and freeboard, depth of sediment and slurry	Description	<u>no change</u>		_____
6	Changes in Vegetation such as being overly lush	Description	<u>no change</u>		_____
7	Obstructive vegetation and trees	Description	<u>no change</u>		_____
8	Animal burrows	Yes	<input checked="" type="radio"/> No	Description	_____
9	Changes to liners	Not Applicable			
10	Spillway Integrity	Description	<u>no change</u>		_____
11	Any other changes which may indicate a potential compromise to impoundment integrity	Description	<u>no change</u>		_____
12	Fugitive Dust issues	Description	<u>none</u>		_____

Date Inspection Performed 1-30-17

Inspection Performed by *Geo Ryznar*