

# CCPC Impoundment "Ashpond" Weekly Inspection

1	Cracks or Bulges	Yes	<input checked="" type="radio"/> No	Description	_____
2	Susidence	Yes	<input checked="" type="radio"/> No	Description	_____
3	Wet or Soft Soil	Yes	<input checked="" type="radio"/> No	Description	_____
4	Changes in Geometry	Yes	<input checked="" type="radio"/> No	Description	_____
5	Elevation of the impounded water and treeboard, depth of sediment and slurry	Description		no change	_____
6	Changes in Vegetation such as being overly lush	Description		no change	_____
7	Obstructive vegetation and trees	Description		no change	_____
8	Animal burrows	Yes	<input checked="" type="radio"/> No	Description	_____
9	Changes to liners	Not Applicable			
10	Spillway Integrity	Description		no change	_____
11	Any other changes which may indicate a potential compromise to impoundment integrity	Description		no change	_____
12	Fugitive Dust Issues	Description		none	_____

Date Inspection Performed 2-19-19

Inspection Performed by Joe Roggen