

CCPC Impoundment "Ashpond" Weekly Inspection

1	Cracks or Bulges	Yes	<input checked="" type="radio"/> No	Description	_____
2	Susidence	Yes	<input checked="" type="radio"/> No	Description	_____
3	Wet or Soft Soil	<input checked="" type="radio"/> Yes	No	Description	seepage at toe of north embankment
4	Changes in Geometry Elevation of the impounded water and freeboard, depth of sediment and slurry	Yes	<input checked="" type="radio"/> No	Description	_____
5		Description	no change		_____
6	Changes in Vegetation such as being overly lush	Description	no change		_____
7	Obstructive vegetation and trees	Description	no change		_____
8	Animal burrows	Yes	<input checked="" type="radio"/> No	Description	_____
9	Changes to liners	Not Applicable			
10	Spillway Integrity Any other changes which may indicate a potential compromise to impoundment integrity	Description	no change		_____
11		Description	no change		_____
12	Fugitive Dust Issues	Description	none		_____

Date Inspection Performed 3-25-19

Inspection Performed by Joe Rogan